



Dear *Drinking Water Specialists* Customer,

Enclosed please find your '*Bang-for-the-Buck*' *Well Water Test Report*.

We have prepared the report with the consumer in mind, taking special care to provide an informative, yet simple to understand format.

The USEPA has designated a Limit or Maximum Contaminant Level for most parameters included in the Essential Indicators Water Test. However, there are some parameters that have not as yet been assigned a MCL. If a parameter has a MCL, it will be shown in the column immediately to the right of that parameter. If the Result for one of these parameters exceeds the MCL, it will be highlighted in **bold red**. If IRB is present, you *should* chlorinate your well.

If you have any questions concerning your report, please e-mail us at support@drinkingwaterspecialists.com.

Please remember that the '*Bang-for-the-Buck*' *Well Water Test* is intended for personal informational purposes only and is not intended for legal or regulatory compliance matters. If a parameter exceeds the USEPA limit, you may wish to retest the source at a local certified laboratory to confirm its presence.

We hope that you find the '*Bang-for-the-Buck*' *Well Water Test* helpful in determining the quality of your drinking water and hope that we can be of service to many of your family members and friends.

Thank you again for your trust in using *Drinking Water Specialists*.

Very truly yours,

Thomas Mullen
Laboratory Director



'Bang-for-the-Buck' Well Water Test Report

Order number: D3905

Source: well

Lab number: A6582

Date Collected: 3/23/2022

Name: Victoria Botkin

Address: 168 Three Springs Rd

City, State, Zip: Nunnely, TN 37137

Location: bathroom tap

BACTERIA

Parameter	Result
Iron-related bacteria (IRB)	present

ESSENTIAL ELEMENTS AND HEAVY METALS

Parameter	MCL (mg/L)	MRL (mg/L)	Result (mg/L)
Aluminum	0.2	0.05	0.85
Antimony	0.006	0.002	nd
Arsenic	0.01	0.002	nd
Barium	2	0.002	nd
Beryllium	0.004	0.001	nd
Boron		0.05	nd
Calcium		0.05	18
Cadmium	0.005	0.001	nd
Carbon		0.05	nd
Cerium		0.005	nd
Cesium		0.005	nd
Total Chromium	0.1	0.01	nd
Chromium 3+		0.005	nd
Hexavalent Chromium		0.005	nd
Cobalt		0.02	nd
Copper	1.3	0.01	0.011
Ferric Iron		0.03	0.43
Ferrous Iron		0.03	nd
Total Iron	0.3	0.03	0.43
Lead	0.01	0.002	nd
Lithium		0.002	nd
Magnesium		0.1	2.86
Manganese	0.05	0.005	nd
Mercury	0.002	0.0001	nd
Nickel	5	0.01	nd
Phosphorus		0.05	nd
Potassium		0.01	0.77
Selenium	0.05	0.002	nd



ESSENTIAL ELEMENTS AND HEAVY METALS (CONT'D)

Parameter	MCL (mg/L)	MRL (mg/L)	Result (mg/L)
Silicon		0.5	nd
Silver	0.1	0.005	nd
Sodium	50	0.1	20.2
Sulfur		0.5	nd
Thorium		0.05	nd
Tin		0.1	nd
Titanium		0.01	nd
Uranium		0.02	nd
Zinc	5	0.01	nd

INORGANICS

Parameter	MCL (mg/L)	MRL (mg/L)	Result (mg/L)
Alkalinity		0.25	80
Ammonia		0.2	nd
Total Carbonate		N/A	60
Bromide		0.1	nd
Chloride	250	0.200	12
Color (units in CU)	15	1	nd
Conductivity (units in μ mhos)		N/A	94
Corrosivity, Langelier Saturation Index		N/A	-0.87
Fluoride	2	0.2	nd
Total Hardness (CaCO ₃)	250	0.25	100
Total Hardness (Grains)		N/A	5.84
Nitrate	10	0.3	nd
Nitrite	1	0.2	nd
pH	6.5-8.5	N/A	7.2
Salinity		N/A	nd
Sulfate	250	0.5	nd
Tannins		0.5	nd
Total Dissolved Solids (TDS)	500	10	52
Turbidity (units in NTU)		0.1	nd

VOLATILE ORGANIC COMPOUNDS (VOC)

Parameter	MCL (μ g/L)	MRL (μ g/L)	Result (μ g/L)
¹ Chloroform (THM)		0.50	nd
¹ Bromodichloromethane (THM)		0.50	nd
¹ Dibromochloromethane (THM)		0.50	nd
¹ Bromoform (THM)		0.50	nd
¹ Total Trihalomethanes (THM)		N/A	nd
Acetone		0.50	nd



VOLATILE ORGANIC COMPOUNDS (VOC) (CONT'D)

Parameter	MCL (µg/L)	MRL (µg/L)	Result (µg/L)
Acrylonitrile		0.50	nd
Allyl Chloride		0.50	nd
2-Butanone		0.50	nd
Carbon Disulfide		0.50	nd
Chloroacetonitrile		0.50	nd
Trans-1,2-Dichloroethene		0.50	nd
1,1-Dichloropropanone		0.50	nd
Diethyl Ether		0.50	nd
Ethyl Methacrylate		0.50	nd
Hexachloroethane		0.50	nd
2-Hexanone		0.50	nd
Methacrylonitrile		0.50	nd
Methylacrylate		0.50	nd
Methyliodide		0.50	nd
Methylmethacrylate		0.50	nd
4-Methyl-2-Pentanone		0.50	nd
Nitrobenzene		0.50	nd
2-Nitropropane		0.50	nd
Pentachloroethane		0.50	nd
Propionitrile		0.50	nd
Tetrahydrofuran		0.50	nd
1-Chlorobutane		0.50	nd
Chloromethane		0.50	nd
Vinyl Chloride		0.50	nd
Dichloroflouromethane		0.50	nd
Chloroethane		0.50	nd
Trichlorofluoromethane		0.50	nd
Bromomethane		0.50	nd
1,1 Dichloroethane	50	0.50	nd
1,1 Dichloroethene	2	0.50	nd
Methylene Chloride	3	0.50	nd
trans-1,2-Dichloroethene	100	0.50	nd
2,2 Dichloropropane		0.50	nd
cis-1,2 Dichloroethene	70	0.50	nd
1,1 Dichloropropene		0.50	nd
Bromochloromethane		0.50	nd
1,1, 1 Trichloroethane	30	0.50	nd
1,2 Dichloroethane	2	0.50	nd
Carbon Tetrachloride	2	0.50	nd
Benzene (BTEX)	1	0.50	nd
Trichloroethylene	5	0.50	nd



VOLATILE ORGANIC COMPOUNDS (VOC) (CONT'D)

Parameter	MCL (µg/L)	MRL (µg/L)	Result (µg/L)
1,2 Dichloropropane	5	0.50	nd
Toluene	1000	0.50	nd
Dibromomethane		0.50	nd
cis-1,3 Dichloropropene		0.50	nd
Tetrachloroethylene	1	0.50	nd
trans-1,3 Dichloropropene		0.50	nd
1,1,2 Trichloroethane	3	0.50	nd
1,2 Dibromomethane		0.50	nd
1,3 Dichloropropane		0.50	nd
1,1,1,2 Tetrachloroethane	1	0.50	nd
Chlorobenzene	50	0.50	nd
Ethylbenzene	700	0.50	nd
o-Xylene		0.50	nd
m,p-Xylene (BTEX)		0.50	nd
Isopropylbenzene		0.50	nd
Styrene	100	0.50	nd
Methyl Tertiary Butyl Ether (MTBE)	70	0.50	nd
1,2,3 Trichloropropane		0.50	nd
1,1,2,2 Tetrachloroethane	1	0.50	nd
1,3,5 Trimethylbenzene		0.50	nd
n-Propylbenzene		0.50	nd
Bromobenzene		0.50	nd
tert-Butylbenzene		0.50	nd
Chlorotoluene-2		0.50	nd
Chlorotoluene-4		0.50	nd
1,2,4 Trimethylbenzene		0.50	nd
sec-Butylbenzene		0.50	nd
n-Butylbenzene		0.50	nd
1,3 Dichlorobenzene	600	0.50	nd
1,4 Dichlorobenzene	75	0.50	nd
p-Isopropyltoluene		0.50	nd
1,2,4 Trichlorobenzene	9	0.50	nd
1,2 Dichlorobenzene	600	0.50	nd
1,2 Dibromo-3-Chloropropane		0.50	nd
Hexachlorobutadiene		0.50	nd
1,2,3 Trichlorobenzene		0.50	nd
Naphthalene	300	0.50	nd
Total Xylenes	1000	0.50	nd



+++++

¹ The following parameters are in a category named Trihalomethanes:

Chloroform (THM)

Bromodichloromethane (THM)

Dibromochloromethane (THM)

Bromoform (THM)

Plus, there is separate parameter named 'Total Trihalomethanes (THM)', which is just that—the total of the 4 individual Trihalomethanes.

If any of the individual Trihalomethanes, or if Total Trihalomethanes have a result of 80 µg/L or greater, the result for that parameter will be colored **RED** and **BOLD**.

+++++

All testing performed using USEPA testing methods

MCL = Maximum Contaminant Level > = greater than < = less than

MRL = Minimum Reporting Level of our test instrument

Result = the actual test result value found in this water sample if ≥ MRL

mg/L = milligram per liter ((parts per million)

µg/L = microgram per liter

nd = Not detected at or above MRL

NTU = unit of Turbidity

µmho = unit of Conductivity

N/A = not applicable for this parameter

Remarks: Parameters highlighted in bold red type are above the standards established by the USEPA for potable water.

Note: Actual pH measurement may be slightly lower or higher than result reported due to transit time of sample or the use of a Reverse Osmosis (RO) filter unit.

Note: This report is intended to be used for informational purposes only and should not be used for regulatory and/or legal purposes.

By: Thomas Mullen
Laboratory Director

*****IMPORTANT*****

If you have a well as the source for your household drinking and bathing water, the EPA and state and local health departments highly recommend that you chlorinate or sanitized your well water every 12 to 24 months. Your health and wellbeing depend on you having safe and healthy drinking water. That's why municipal water supplies are continually being sanitized. It is also the only way to eliminate bad tasting and bad smelling water. To learn more about the why and how behind chlorinating your well, go to our web site:

www.drinkingwaterspecialists.com/well-water-wellness-kit/